

# Certificate of Compliance

**Certificate Number:**

EX15279-Vol1

**Report Reference:**

EX15279-20090320

**Issue Date:**

2025-10-28

Issued to:

**HILTI AKTIENGESELLSCHAFT  
FELDKIRCHERSTRASSE 100  
PO BOX 333 SCHAAN 9494  
Liechtenstein**

This certificate confirms that representative samples of:  
**VFXT - Hangers, Pipe**

**See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**Additional Information:**

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# CERTIFICATE OF COMPLIANCE

**Certificate number** EX15279-Vol1  
**Report reference** EX15279-20090320  
**Date** 2025-10-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Hanger

Model	Hanger Type	Rod Size, inches	Nominal Pipe Size, inches	Comments
LH	Band Hanger	3/8	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4	-
		1/2	6, 8	-
SDC-EG	Clevis Hanger	3/8	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	-
		1/2	2-1/2, 3	-
		5/8	4, 5	-
		3/4	6, 8	-
		7/8	10, 12	-

# Certificate of Compliance

**Certificate Number:**

EX15279-Vol1

**Report Reference:**

EX15279-20050113

**Issue Date:**

2025-10-28

Issued to:

**HILTI AKTIENGESELLSCHAFT**  
**FELDKIRCHERSTRASSE 100**  
**PO BOX 333 SCHAAN 9494**  
**Liechtenstein**

This certificate confirms that representative samples of:  
**VFXT - Hangers, Pipe**

**See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# CERTIFICATE OF COMPLIANCE

**Certificate number** EX15279-Vol1  
**Report reference** EX15279-20050113  
**Date** 2025-10-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Hanger

Model	Hanger Type	Rod Size, inches	Nominal Pipe Size, inches	Comments
SLC-EG	Clevis Hanger	3/8	2, 2-1/2	-
		1/2	3	-
		5/8	4, 5	-
		3/4	6, 8	-

# Certificate of Compliance

**Certificate Number:**

EX15279-Vol1

**Report Reference:**

EX15279-20230808

**Issue Date:**

2025-10-28

Issued to:

**HILTI AKTIENGESELLSCHAFT  
FELDKIRCHERSTRASSE 100  
PO BOX 333 SCHAAN 9494  
Liechtenstein**

This certificate confirms that representative samples of:  
**VFXT7 - Hangers, Pipe Certified for Canada**

**See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# CERTIFICATE OF COMPLIANCE

**Certificate number** EX15279-Vol1  
**Report reference** EX15279-20230808  
**Date** 2025-10-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Hanger

Model	Hanger Type	Rod Size, inches	Nominal Pipe Size, inches	Comments
LH	Band Hanger	3/8	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4	-
		1/2	6, 8	-
SDC-EG	Clevis Hanger	3/8	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	-
		1/2	2-1/2, 3	-
		5/8	4, 5	-
		3/4	6, 8	-
		7/8	10, 12	-

# Certificate of Compliance

**Certificate Number:**

EX15279-Vol1

**Report Reference:**

EX15279-20050113

**Issue Date:**

2025-10-28

Issued to:

**HILTI AKTIENGESELLSCHAFT  
FELDKIRCHERSTRASSE 100  
PO BOX 333 SCHAAN 9494  
Liechtenstein**

This certificate confirms that representative samples of:  
**VFXT7 - Hangers, Pipe Certified for Canada**

**See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# CERTIFICATE OF COMPLIANCE

**Certificate number** EX15279-Vol1  
**Report reference** EX15279-20050113  
**Date** 2025-10-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Hanger

Model	Hanger Type	Rod Size, inches	Nominal Pipe Size, inches	Comments
SLC-EG	Clevis Hanger	3/8	2, 2-1/2	-
		1/2	3	-
		5/8	4, 5	-
		3/4	6, 8	-

# Certificate of Compliance

**Certificate Number:**

EX15279-Vol2

**Report Reference:**

EX15279-20170814

**Issue Date:**

2025-10-28

Issued to:

**HILTI AKTIENGESELLSCHAFT  
FELDKIRCHERSTRASSE 100  
PO BOX 333 SCHAAN 9494  
Liechtenstein**

This certificate confirms that representative samples of:  
**VFXT - Hangers, Pipe**

**See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# CERTIFICATE OF COMPLIANCE

**Certificate number** EX15279-Vol2  
**Report reference** EX15279-20170814  
**Date** 2025-10-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Hanger

Model	Hanger Type	Rod Size	Nominal Pipe Size, inches	Comments
MP-SPN	Loop Hanger	M10	3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4	-
MP-SPN	Loop Hanger	M12	133 mm, 5, 159 mm, 6	-
MP-SPN	Loop Hanger	M16	219.1 mm	-
MP-US	U Strap	N/A	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 108 mm, 4, 133 mm, 5, 159 mm, 6, 8, 10, 12	Can be installed on the bottom, side, or top (surge restraint) orientations
MP-UB (metric)	U Bolt	N/A	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 108 mm, 4, 133 mm, 5, 159 mm, 6, 8, 10, 12	Metric threads; Can be installed on the bottom, side, or top (surge restraint) orientations
MP-UB (NPT)	U Bolt	N/A	1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10, 12	NPT Threads; Can be installed on the bottom, side, or top (surge restraint) orientations

# Certificate of Compliance

**Certificate Number:**

EX15279-Vol2

**Report Reference:**

EX15279-20170814

**Issue Date:**

2025-10-28

Issued to:

**HILTI AKTIENGESELLSCHAFT  
FELDKIRCHERSTRASSE 100  
PO BOX 333 SCHAAN 9494  
Liechtenstein**

This certificate confirms that representative samples of:  
**VFXT7 - Hangers, Pipe Certified for Canada**

**See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# CERTIFICATE OF COMPLIANCE

**Certificate number** EX15279-Vol2  
**Report reference** EX15279-20170814  
**Date** 2025-10-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Hanger

Model	Hanger Type	Rod Size	Nominal Pipe Size, inches	Comments
MP-SPN	Loop Hanger	M10	3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4	-
MP-SPN	Loop Hanger	M12	133 mm, 5, 159 mm, 6	-
MP-SPN	Loop Hanger	M16	219.1 mm	-
MP-US	U Strap	N/A	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 108 mm, 4, 133 mm, 5, 159 mm, 6, 8, 10, 12	Can be installed on the bottom, side, or top (surge restraint) orientations
MP-UB (metric)	U Bolt	N/A	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 108 mm, 4, 133 mm, 5, 159 mm, 6, 8, 10, 12	Metric threads; Can be installed on the bottom, side, or top (surge restraint) orientations
MP-UB (NPT)	U Bolt	N/A	1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10, 12	NPT Threads; Can be installed on the bottom, side, or top (surge restraint) orientations

# Certificate of Compliance

**Certificate Number:**

EX15279-Vol3

**Report Reference:**

EX15279-19940425

**Issue Date:**

2025-10-28

Issued to:

**HILTI AKTIENGESELLSCHAFT  
FELDKIRCHERSTRASSE 100  
PO BOX 333 SCHAAN 9494  
Liechtenstein**

This certificate confirms that representative samples of:  
**VFXT - Hangers, Pipe**

**See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# CERTIFICATE OF COMPLIANCE

**Certificate number** EX15279-Vol3  
**Report reference** EX15279-19940425  
**Date** 2025-10-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Hanger

Model	Hanger Type	Rod Size, mm	NPS, in.	Comments
MF-TSH	Trapezoidal Bracket	10	3/4, 1	-
MP-MS	Pipe Clamp	10	1/2, 3/4, 1, 1-1/4, 1-1/2, 54/57mm, 2, 68/72mm, 2-1/2, 3	-
MP-MS	Pipe Clamp	12	101.6mm, 4, 117mm, 125mm, 127mm, 133mm, 5, 152.4mm, 159mm, 6	-
MP-SP	Band Hanger	10	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4	-
MP-SP	Band Hanger	12	5, 6	-
MP-SP	Band Hanger	16	8	-

# Certificate of Compliance

**Certificate Number:**

EX15279-Vol3

**Report Reference:**

EX15279-19940425

**Issue Date:**

2025-10-28

Issued to:

**HILTI AKTIENGESELLSCHAFT  
FELDKIRCHERSTRASSE 100  
PO BOX 333 SCHAAN 9494  
Liechtenstein**

This certificate confirms that representative samples of:  
**VFXT7 - Hangers, Pipe Certified for Canada**

**See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# CERTIFICATE OF COMPLIANCE

**Certificate number** EX15279-Vol3  
**Report reference** EX15279-19940425  
**Date** 2025-10-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Hanger

Model	Hanger Type	Rod Size, mm	NPS, in.	Comments
MF-TSH	Trapezoidal Bracket	10	3/4, 1	-
MP-MS	Pipe Clamp	10	1/2, 3/4, 1, 1-1/4, 1-1/2, 54/57mm, 2, 68/72mm, 2-1/2, 3	-
MP-MS	Pipe Clamp	12	101.6, 4, 117mm, 125mm, 127mm, 133mm, 5, 152.4mm, 159mm, 6	-
MP-SP	Band	10	Up to 4	-
MP-SP	Band	12	5, 6	-
MP-SP	Band	16	8	-

# Certificate of Compliance

**Certificate Number:**

EX15279-ML

**Report Reference:**

EX15279-20070919

**Issue Date:**

2025-10-28

Issued to:

**HILTI AKTIENGESELLSCHAFT  
FELDKIRCHERSTRASSE 100  
PO BOX 333 SCHAAN 9494  
Liechtenstein**

This certificate confirms that representative samples of:

**VFXT - Hangers, Pipe  
VFXT7 - Hangers, Pipe Certified for Canada**

**See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**Additional Information:**

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# CERTIFICATE OF COMPLIANCE

**Certificate number** EX15279-ML  
**Report reference** EX15279-20070919  
**Date** 2025-10-28

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Hanger

Model	Hanger Type	Rod Size, mm	NPS, in.	Comments
MAB-M10	Universal Beam Clamp	10	Up to 4	-
MAB-11	Universal Beam Clamp	10	Up to 4	-
MAB-M12	Top Beam Clamp	12	Up to 8	-
MAB-13	Top Beam Clamp	12	Up to 8	-
MAB-M16	Universal Beam Clamp	16	Up to 12	-
MAB-17	Universal Beam Clamp	16	Up to 12	-